

- security - Evac probs. Who's in charge?
  - Radio freq?
- Kinney - Reviewed incident
  - Evac prob
  - Decon thoroughness -
  - Pers stepping into 1<sup>st</sup> tank
  - Security s.B. at C.P. (vest)
- King - Evac prob
  - staying area not clean
- Marshall - I.C. etc should remain at one location
- Menoit - N. Boeing Field & PL 2 work together w/ S.F.D.
- Safety - Evac communication
  - Shop Evac plan
  - Responders in sun in level 'A'
- O'Neill - Back up s.B. suited as entry
- Vye - Reviewed incident times and C.P. Layout
- Ray - Hot Zone violated by S.F.D.
  - Barricades "
  - Better comm for back-up
- Balyz - Deferred concerns to future meeting
- Dodds - Discussed command structure
  - Ident. Key pers (vests)

IRA - Response S.B. site specific when discuss Neutralization

- Felt we used overkill in treatment

Tye - Things won't be so complex as we work together

safety - Zone barriers broke down  
- command was crowded

Bob - " shifted

- Moving Decou & Equip Truck

- SFD violate Hot Zone

- security did better even with mixed signals

Gary - Discussed command structure and locations within zone

YVETTE - set up was confused

- ETT hose line training

- legs taped? on 2nd team

Tim - One man in Zone by self

- One air too long

- Decou didn't believe

" " Opened Entry suits

Paul - " " "

Webb SFD - v.p. where was it

- command who? Vets

- Zones & corridor marking

- SFD No Vitals

- Decon pens not properly dressed
- clothes come off when suit torn.
- Joint Drills w/ SFD, Tukwila & U.S.
- Take readings while Neutralization
- Suit I.D.

Phil S.F.D. - should try to inc.

bdy air pressure

- NEVER WAS A C.P.
- 1<sup>ST</sup> Joint ops w/ Non S.F.D.
- Vests for S.F.D.
- Safety off. " ?
- Decon done by selves
- Boeing shouldn't have pulled S.F.D. year.
- Commed broke down at 2<sup>ND</sup> entry
- Medics avail for all.

Issue - Zones were marked O.K.

- Back up team location